



To whom it may concern

Confirmation of Test Results

Polyseam Ltd hereby confirm we have conducted fire tests according to EN 1366-3:2009 on the specification and with the result listed below. The tests will be included in a later upgrade of ETA 13/0673 for the product Protecta FR Board.

Products: Protecta FR Board 50mm DS
Protecta FR Acrylic
Protecta ServiceCoat FR-1

Construction: Minimum wall thickness of 100 mm and comprise steel studs or timber studs* lined on both faces with minimum 2 layers of 12.5 mm thick boards, or comprise concrete, aerated concrete or masonry, with a density of $\geq 650 \text{ kg/m}^3$

Aperture: Maximum 1200mm high and unlimited width

Installation: Two boards positioned flush on both sides of the construction. All gaps must be sealed with Protecta FR Acrylic on both sides. Steel pipes must be coated back with Protecta ServiceCoat FR-1 both sides.

Test reports: Warringtonfire reports no. WF392646 item H1 and WF398517 item A1

Results: $\leq \text{Ø } 114\text{mm}$ steel pipes with coat-back 200mm both sides at 1000 microns thick dry film to **EI 45 C/U** and E 120 C/U.

$\leq \text{Ø } 65\text{mm}$ steel pipes with coat-back 200mm both sides at 1500 microns thick dry film to **EI 60 C/U** and E 120 C/U.

Best regards,


Kjetil Bogstad
CEO

T: +44 (0) 1484 421036
F: +44 (0) 1484 500445
E: post.uk@polyseam.com
www.polyseam.com

Polyseam Ltd.
15 St Andrews Road
Huddersfield
West Yorkshire
HD1 6SB, UK.

Intelligent Chemistry.

Registered in England No: 2839491

with compliments

